CEPROM

PRODUCT CERTIFICATION BODY

CEPROM ® S.A.

440240 Satu Mare, str. Fântânele, No. 23/A, Romania
tel. +40.0361.804795; fax +40.0361.804796
www.ceprom.ro ; e-mail: ceprom@ceprom.ro

CERTIFICATE OF CONFORMITY

No. 4985-CI-32026

Technical File No. *4985-CI-32026/STE09112609S*

Applicant:	**Manufacturer:**
SHANGHAI MATIS ELECTRIC CO., LTD.	***SHANGHAI MATIS ELECTRIC CO., LTD.***
Room318-320, No.83,West Huanghu Road, Pudong, Shanghai, China 201306	*Room318-320, No.83,West Huanghu Road, Pudong, Shanghai, China 201306*

Description of product:

Product: ***AUTO RECLOSER***

Model: ***see Annex***

Reference standards: *EN 63024:2018*

Based on our assessment we confirm that the product is in accordance with the technical requirements of the above standards and hence fulfils the technical requirements of the

Low Voltage Directive 2014/35/EU

The manufacturer shall affix the CE marking to each product that is in conformity with those described in this Certificate, after completion of the EC Declaration of Conformity and in accordance with the above directive.

The manufacturer must ensure the assessment of conformity with internal controls on the manufacture of the above product, in accordance with Annex VIII of 2006/42/EC Directive;

The assessment activity for the product described in this Certificate of Conformity was carried out in compliance with Scheme 1a, cf. EN ISO/IEC 17067:2013 with Assessment Report and doesn't belong to the products listed in Annex IV of 2006/42/EC Directive which is under harmonised European Union product legislation.

This Certificate of Conformity was issued on voluntary basis of manufacturer and is only valid for the product and configuration described (annex), in conjunction with the detailed test data and with all applicable legal requirement for the product.

Annex: ***Product identification - 2 pages***

Issuing Date: *25.09.2026*



EUROPEAN UNION
Satu Mare, Romania

GENERAL MANAGER
eng. Cristian SOPONOȘ

CEPROM–CERT Manager
eng. Vasile ZELE

CEPROM S.A. Satu Mare

E.S.

Partial reproduction of this certificate is not allowed
This Certificate of Conformity is valid only if it is published on the site www.ceprom.ro

CEPROM

PRODUCT CERTIFICATION BODY

CEPROM ® S.A.

440240 Satu Mare, str. Fântânele, No. 23/A, Romania
tel. +40.0361.804795; fax +40.0361.804796
www.ceprom.ro ; e-mail: ceprom@ceprom.ro

ANNEX
to the Certificate of Conformity no. 4985-CI-32026

PRODUCT IDENTIFICATION

The Product:	***AUTO RECLOSER***
*model:	***MT56AS, MT56AR, MT56SD, MT56AI , MT56AW, MT56RI, MT56RW, MT56RS***
*manufactured by:	***SHANGHAI MATIS ELECTRIC CO., LTD.***
*headquarters address:	*Room318-320, No.83,West Huanghu Road, Pudong, Shanghai, China 201306*
*place of manufacture:	*Room318-320, No.83,West Huanghu Road, Pudong, Shanghai, China 201306*
*domain of use:	*The MT56 series auto recloser is designed to automatically reclose the associated breakers after checking the fault. It is compatible with MCB/RCCB/RCBO both from Matis and EATON and the corresponding auxiliary OF/SD .*

Technical File content:

- *General description of the equipment;*
- *Conceptual design and manufacturing drawings and schemes of components;*
- *Instruction manual;*
- *The list of standards applied;*
- *Test report;*
- *Declaration of conformity;*
- *The internal measures implemented to ensure equipment conformity with LVD.*

CEPROM-CERT Manager
eng. Vasile ZELE



Partial reproduction of this certificate is not allowed
This Certificate of Conformity is valid only if it is published on the site www.ceprom.ro

CEPROM

ANNEX
to the Certificate of Conformity no. 4985-CI-32026

PRODUCT IDENTIFICATION

The Product: ***AUTO RECLOSER***

*constructive and functional characteristics:

Model	*M.U.*	*MT56AS*	*MT56AI*	*MT56AW*	*MT56AR*	*MT56RS*
Power Supply	*V*	*AC230*	*AC230*	*AC230*	*AC230*	*AC230*
Standard Input Power	*W*	*<1VA*	*<1VA*	*<1VA*	*<1VA*	*<1VA*
Delay Time	*s*	*15/90/300*	*15/60/300*	*15/60/300*	*15/90/500*	*15/60/300*
Number of Reclosing action	*-*	*3*	*3*	*3*	*3*	*3*

Model	*M.U.*	*MT56RI*	*MT53RW*	*MT56SD*
Power Supply	*V*	*AC230*	*AC230*	*AC230*
Standard Input Power	*W*	*<1VA*	*<1VA*	*<1VA*
Delay Time	*s*	*15/90/300*	*15/90/300*	*15/60/300*
Number of Reclosing action	*-*	*3*	*3*	*1-10 adjustable*

CEPROM-CERT Manager
eng. Vasile ZELE

S.C. CEPROM S.A. SATU MARE CEPROM CERT

Partial reproduction of this certificate is not allowed
This Certificate of Conformity is valid only if it is published on the site www.ceprom.ro